



**NOTES:**

- ① PCC shall be Class 3, colored (Davis Adobe #5964) with salt finish. Salt shall be coarse water softner salt spread at a rate of 1/2 lb per 100 square feet. Salt finish shall be applied to sidewalk area only. Salt finish shall not be applied to curbs, gutters, or ramps.
- ② Tile to be TerraTile unglazed ceramic tile, Red, 12" square, or approved equal.
- ③ Tile shall be set in mortar bed, grout to match colored concrete (Davis Adobe #5964).
- ④ Surface of sidewalk to slope 2% toward curb.
- ⑤ For driveways increase thicknesses to: Aggregate base-6"; Concrete-6" min. thickness.
- ⑦ Rebar, #4 @ 24" o.c., full width of sidewalk, curb end bent 4" x 90°.
- ⑧ Smooth steel dowels, 1/2" @ 24" o.c., 18" long, to be sleeved or greased.
- ⑨ For curb and gutter, see Engineering Standard #4030.
- ⑩ No tile shall be set in mortar prior to approval of tile by City Engineer.
- ⑪ All new installations shall include curb and gutter.
- ⑫ Tiles shall be trimmed or arranged to allow mortar joints to coincide with expansion joints, tree wells, etc. Tiles adjacent to curb ramps shall come up to but terminate at the grooved curb ramp border. Flush ramps without grooves, tile shall terminate at truncated domes.
- ⑬ Expansion joints and weakened plane joints shall be per Eng. Std. #4110.
- ⑭ Pavement removal and repair shall be per Eng. Std. #4110.
- ⑮ See Engineering Standard #1010 for further requirements.
- ⑯ All sign posts, parking meter posts, and new utility vaults shall be located behind the tile row and shall be installed per City Eng. Stds.
- ⑰ All new and existing wells, boxes, lids and covers shall be stained or coated to match surrounding sidewalk. Stains and coatings shall be submitted to the Engineer for approval prior to application. Lids and covers may be cast iron or dark galvanized slip-resistant diamond-plate. Lids and covers in traffic areas shall be traffic rated.
- ⑱ Mission Style Sidewalk may only be installed in the Mission Sytle Sidewalk District unless specifically authorized by the City Engineer.

REVISIONS	BY	APP	DATE
Rev. notes 1, 3, 7 & 11	DVB	BL	10-08
Revised notes 11 - 18	MH	BL	10-09
Rev. 12, 14, 15, add 16	DVB	BL	10-06
STANDARD CURRENT AS OF:		January 2010	



MISSION STYLE  
SIDEWALK